



Fire Marshal Inspection Requirements

- A minimum of one 2A-10BC fire extinguisher for each 3,000 square feet of floor is not to exceed 75 feet of travel distance.
- All extinguishers must be checked and tagged for proper maintenance.
- Automatic sprinkler systems have been serviced within one year and valves are open and supervised. (Chained or electrically monitored)
- Sprinkler/Standpipe Fire Department Connections (FDC) are provided with caps.
- A minimum of 18 inches of clearance is provided and maintained between the top of any storage and sprinkler heads or any overhead obstructions.
- Emergency lights are tested and working.
- Fire alarm system is working properly.
- Fire Pump/Emergency Generators are tested weekly and logged.
- Exit lights illuminated.
- Designated exits are unlocked and clear of any obstructions.
- Stairwell doors equipped with self-closures and proper hardware.
- Extension cords do not exceed 6 feet in length and all electrical wiring is installed according to the National Electric Code. Panels are clear and accessible.
- Cooking equipment, vent hoods, filters, and ducts free of excess grease.
- Automating smothering systems protecting cooking surfaces have been inspected within the last six months.
- Minimum of a K-type fire extinguisher mounted in the kitchen area.
- Compressed gas cylinders securely chained or strapped in the vertical position.
- No Smoking signs are posted and maintained at all fuel pump islands with a minimum of one 2A-20 BC fire extinguisher within 75 feet of travel distance.
- Combustible waste kept to a minimum.
- Approved housekeeping
- Address posted on the street side of the building with a 4-inch minimum height number.

Call Fire Marshall Jeff Klaren with any questions at 864.873.8680.